

Application #	Meter Number	SA Number	Address	Xfmr Size (kVA)	Gross Inverter Gen (kW)	Notes / Comments / Status	# of meters	Cost @ \$5/meter	Cost @ \$20/meter	Cost @ \$2.70/meter	Estimated monthly production (kWh)	Production value @ \$0.15/kWh	Total cost @ \$20/meter
SCE-77221	254000-005918	3-003-5019-90	3242	75	56	PTO 3/15/17	195	975	3900	526.5	9415	1412.25	19500
SCE-77223	254000-011437	3-003-4332-79	5510	75	44	PTO 3/17/17	44	220	880	118.8	6388	958.2	4400
SCE-77224	254000-016548	3-003-4315-18	3420	45	39	PTO 3/2/17	45	225	900	121.5	6580	987	4500
SCE-77226	254000-016424	3-003-5019-88	3243	75	50	PTO 3/9/17	34	170	680	91.8	8189	1228.35	3400
SCE-77234	254000-024755	3-001-2003-73	2381	75	63	PTO 3/7/17	12	60	240	32.4	11183	1677.45	1200
SCE-77841	254000-024542	3-001-2000-45	2400	75	63	PTO 3/2/17	16	80	320	43.2	10856	1628.4	1600
SCE-77847	254000-013083	3-003-4319-35	5372	75	56	PTO 3/2/17	20	100	400	54	9415	1412.25	2000
SCE-77843	254000-024752	3-001-2003-31	2353	45	36	PTO 7/17/17 part. w/ 2391	5	25	100	13.5	6388	958.2	1100
SCE-77839	254000-024541	3-001-2000-27	2399	75	51	Interconnection made at 2403							
SCE-77229	254000-008339	3-001-2000-19	2397	75	60	PTO 3/17/17	9	45	180	24.3	10305	1545.75	900
SCE-77232	254000-008337	3-001-2000-08	2393	75	60	Interconnection made at 2390							
SCE-77231	256000-216339	3-001-2000-12	2394	75	68	PTO 4/22/17, SCE work comp. 8/3	20	100	400	54	11727	1759.05	2400
SCE-112938	254000-001740	3-001-1999-47	2391	45	24	PTO 7/17/17 part. w/ 2353	6	30	120	16.2	4265	639.75	1320
SCE-112941	254000-024543	3-001-1832-25	2403	150	51	PTO 7/17/17	4	20	80	10.8	9041	1356.15	880
SCE-112942	254000-001741	3-001-1999-88	2390	75	60	PTO 7/17/17	8	40	160	21.6	10653	1597.95	1760

All sites are on TOU-GS-1-A schedule

TOTALS:

418

2090

8360

1128.6

114405

17160.75

44960